

July 2017

REPUBLIC

MISSOURI

GROWING TOGETHER



AMERICANS WITH DISABILITIES ACT
transition plan 2nd quarter update





While continuing our commitment to ensuring access for all citizens of Republic, the City of Republic maintains an updated catalog of all repairs and barriers removed from previously identified ADA accessibility issues. These issues were formally documented in the City's adopted ADA transition plans and include all city owned buildings and parks, and sidewalks in public right of way. This update will be available on the City's website after each quarter beginning July 2017 and is also available by request at any time using the below contact information. As always, striving to do the right thing at the right time for the right reason.

To receive this document in alternate formats, contact the office of the ADA Coordinator or City Clerk.

City Clerk
213 N. Main St.
Republic, MO 65738
(417) 732-3100
(417) 732-3149 fax

ADA Coordinator
221 N. Main St.
Republic, MO 65738
(417) 732-3400
(417) 732-3499 fax

adacompliance@republicmo.com

Program, Facility, Activity, Service	Individual Feature or Characteristic	Existing Barrier Description / Findings	Cost estimate for barrier removal		Estimated Date of Removal	Date of Removal
			Low	High		
					Complete	In Progress
Police Building	Parking lot	Install van accessible signage at spaces 60" from ground. Restripe accessible space on west side of building to accommodate 5ft wide aisle to right of parking space.	155.00	190.00	FY2018	
Police Building	Pedestrian access to building	Correct vertical fault on sidewalk west of front entry door.	600.00	850.00	FY2018	
Police Building	Pedestrian access to building	Correct vertical fault on main sidewalk to the front entry door.	450.00	700.00	FY2018	
Police Building	Front ingress	Adjust inner and outer entry doors for 5lb max. Opening pressure and 5 seconds closing time.	160.00	240.00	FY2018	
Police Building	Police customer service counter	Lower counter height to 36" within a 36" wide opening.	3,000.00	3,500.00	FY2023	
Police Building	Lobby toilet room Men's	Move toilet paper holders throughout building to allow 1.5" space from grab bars and center between 7-9" from front of toilets. Install pull handles on accessible stall doors. Lower urinal lip to max 17" AFF. Adjust door to open with less than 5 lbs. pressure and close no less than 5 sec. Lower mirror to 40" maximum height to reflective surface.	1,105.00	1,690.00	FY2024	
Police Building	Lobby toilet room Women's	Move toilet paper holders throughout building to allow 1.5" space from grab bars and center between 7-9" from front of toilets. Install pull handles on accessible stall doors. Adjust door to open with less than 5 lbs. pressure and close no less than 5 sec. Lower mirror to 40" maximum height to reflective surface.	805.00	1,190.00	FY2023	
Police Building	Doorway to court clerk window	Adjust inner and outer entry doors for 5lb max. opening pressure and 5 seconds closing time.	40.00	60.00	FY2019	
Police Building	Court clerk customer service counter	Lower counter height to 36" within a 36" wide opening.	1,000.00	1,500.00	FY2020	
Police Building	Doorway to courtroom	Adjust inner and outer entry doors for 5lb max. opening pressure and 5 seconds closing time.	40.00	60.00	FY2020	
Police Building	Doorway to interrogation room and elevator	Replace double doorway with single 36" wide doorway to eliminate single working 26" wide opening during business hours.	500.00	800.00	FY2020	
Police Building		Total Estimates Low/High	7,855.00	10,780.00		0/12
Republic Community Center	Parking lot Front	Reduce slope within accessible parking spaces to no steeper than 1:48. Install van accessible space signage where appropriate (3 spaces).	2,400.00	3,000.00	FY2018	
Republic Community Center	Pedestrian access between Comm. Ctr. and Activities Building	Reduce cross slope to no more than 1: 48.	5,600.00	6,500.00	FY2025	
Republic Community Center	Front pedestrian ingress	Adjust entry door to open with no more than 5 lbs. force and close in no less than 5 seconds.	20.00	30.00	FY2017	
Republic Community Center	West ingress/concessions	Install signage giving direction to accessible entrance	40.00	75.00	FY2028	
Republic Community Center	West outdoor alcove pedestrian access	Install signage giving direction to accessible entrance	40.00	75.00	FY2028	
Republic Community Center	West outdoor alcove picnic tables	Provide 1 wheelchair accessible seat at tables	700.00	900.00	FY2029	
Republic Community Center	Meeting room A	Adjust entry door to open with no more than 5 lbs. force and close in no less than 5 seconds.	20.00	30.00	FY2017	

Program, Facility, Activity, Service	Individual Feature or Characteristic	Existing Barrier Description / Findings	Cost estimate for barrier removal		Estimated Date of Removal	Date of Removal
			Low	High		
					Complete	In Progress
Republic Community Center	Meeting room B	Adjust entry door to open with no more than 5 lbs. force and close in no less than 5 seconds.	20.00	30.00	FY2017	
Republic Community Center	Main (East) Hall Toilet room Men's	Adjust door closer to 5 lbs and 5 seconds, lower mirror to 40" AFF, lower coat hook to 48" AFF, Move TP dispenser,	80.00	125.00	FY2022	
Republic Community Center	Main (East) Hall Toilet room Women's	Adjust door closer to 5 lbs and 5 seconds, lower mirror to 40" AFF, lower coat hook to 48" AFF, Move TP dispenser, make stall door self-closing, install stall door pull,	200.00	290.00	FY2023	
Republic Community Center	showers/lockers men	Adjust door closer to 5 lbs and 5 seconds, lower coat hook to 48" AFF, Move TP dispenser,	50.00	75.00	FY2022	
Republic Community Center	showers/lockers women	Adjust door closer to 5 lbs and 5 seconds, lower coat hook, move TP dispenser, Install loop handle on stall door,	100.00	140.00	FY2022	
Republic Community Center	Meeting room (North Hall) toilet room Men's	Adjust entry door to open with no more than 5 lbs. force and close in no less than 5 seconds. Move clothing hooks to 48" AFF, lower 1 urinal to 17" at lip AFF, move TP dispenser to allow 12" from grab bar, add closer to stall door,	420.00	675.00	FY2023	
Republic Community Center	Meeting room (North Hall) toilet room Women's	Adjust entry door to open with no more than 5 lbs. force and close in no less than 5 seconds. Move clothing hooks to 48" AFF, install loop handle on stall door, move TP dispenser to allow 12" from grab bar, add closer to stall door,	120.00	175.00	FY2023	
Republic Community Center	Walking track unisex toilet room	Adjust door to open with no more than 5 lbs. force and close in no less than 5 seconds, install insulation at lavatory trap, move TP dispenser,	95.00	145.00	FY2023	
Republic Community Center	Family changing room/shower room	Adjust door to open with no more than 5 lbs. force and close in no less than 5 seconds. Lower mirror to 40" AFF, move TP dispenser,	65.00	105.00	FY2023	
Republic Community Center		Total Estimates Low/High	9,970.00	12,370.00		0/16
Cox Health Fitness Center	Parking lot East	Reduce slope in accessible parking spaces to no more than 1:48. Provide accessible parking signage in 1 space. Provide van accessible signage at one space.	2,890.00	3,370.00	FY2020	
Cox Health Fitness Center	Pedestrian access to building - East	Reduce slope at pedestrian access to less than 1:20.	1,600.00	1,870.00	FY2020	
Cox Health Fitness Center	Body Assessments / Massage Room - 2nd floor	Clear 36" pathway of obstruction.	0.00	0.00	Not stated	
Cox Health Fitness Center	Child Care Room - 1st floor	Adjust door to open with 5 lbs. force or less and close in no less than 5 seconds.	20.00	30.00	FY2026	
Cox Health Fitness Center	Exercise equipment	Move exercise equipment to allow for 30" w X 48" d clear floor space for transfer beside at least one of each type of equipment.	0.00	0.00	Not stated	
Cox Health Fitness Center		Total Estimates Low/High	4,510.00	5,270.00		0/5
Activities Building	Parking lot	Reduce slope of accessible parking to less than 1:48 in all directions. Install van accessible parking signage where appropriate.	3,200.00	4,000.00	FY2018	
Activities Building	Pedestrian ingress front	Reduce slope of sidewalk to less than 1:20. Reduce slope of curb ramp serving street crossing and entrance walk. Reduce slope of entrance walk. Ensure accessible entrance is marked with sign of accessibility. Install signage indicating which entrance is accessible and in what direction to travel for access. Create level surface on outside of main door for maneuvering. Adjust main doors to take at least 5 seconds to close.	8,000.00	9,350.00	FY2019	

Program, Facility, Activity, Service	Individual Feature or Characteristic	Existing Barrier Description / Findings	Cost estimate for barrier removal		Estimated Date of Removal	Date of Removal
			Low	High		
					Complete	In Progress
Activities Building	Northeast ingress to/from playground	Construct accessible route from northeast gymnasium exit to provide access to playground equipment and for emergency exit from building.	3,600.00	5,125.00	FY2026	
Activities Building	Meeting room C	Adjust 2 doors to open with no more than 5lbs force and close in not less than 5 seconds. Install lever handles. Install signage at doorway.	115.00	170.00	FY2024	
Activities Building	Kitchen	Adjust door to open with no more than 5lbs force and close in not less than 5 seconds. Install lever handle.	80.00	120.00	FY2028	
Activities Building	Meeting rooms upstairs	Create accessible route to activity rooms on second floor. Install signage at doorways.	0.00	4,000.00	FY2025	
Activities Building	Gymnasium entry doors - SE	Adjust door to open with no more than 5lbs force and close in not less than 5 seconds. Install lever handle.	20.00	30.00	FY2023	
Activities Building	Gymnasium entry doors - E middle	Install lever handle on door.	60.00	90.00	FY2023	
Activities Building	Gymnasium East (middle) door to bath hall	Install lever handle on door.	60.00	90.00	FY2023	
Activities Building	Toilet room women's	Insulate lavatory pipes. Install ADA lavatory handles. In accessible toilet stall: install 42" grab bar at least 12" from rear corner, Install 36" grab bar on rear wall, move TP dispenser upward to allow 12" above grab bar, make stall door self-closing and swing outward, Install loop-style pulls on both sides of stall door, alter accessible compartment to ADA standards,	1,675.00	2,145.00	FY2024	
Activities Building	Toilet room men's	Insulate lavatory pipes. In accessible toilet stall: install 42" grab bar at least 12" from rear corner, Install 36" grab bar on rear wall, move TP dispenser upward to allow 12" above grab bar, install loop-style pulls on both sides of stall door, alter accessible compartment to ADA standards,	3,085.00	3,885.00	FY2024	
Activities Building		Total Estimates Low/High	19,895.00	29,005.00		0/11
Republic Aquatic Center (RAC)	Parking lot	Reduce slope in accessible parking spaces to less than 1:48.	3,200.00	4,000.00	FY2021	
Republic Aquatic Center (RAC)	Pedestrian access to building	Reduce cross slope in sidewalk near change of direction. Reduce running slope at curb ramps.	4,320.00	5,040.00	FY2022	
Republic Aquatic Center (RAC)	Ticket counter / entrance	Lower counter to 36" for 36" width minimum.	1,000.00	1,500.00	FY2023	
Republic Aquatic Center (RAC)	Women's Toilet room	Lower mirrors to 40" AFF, move TP dispenser 12" above grab bar, make ADA stall door self-closing, install door pulls on both sides of stall door, ensure door swings outward.	165.00	240.00	FY2023	
Republic Aquatic Center (RAC)	Men's Toilet room	Lower mirrors to 40" AFF, move TP dispenser 12" above grab bar, install door pulls on both sides of stall door, ensure door swings outward, repair ADA shower faucet handle,	185.00	270.00	FY2023	
Republic Aquatic Center (RAC)	concessions seating / picnic tables	Provide 1 additional accessible seat at tables.	20.00	40.00	FY2026	2016
Republic Aquatic Center (RAC)	Party Zone seating / picnic tables	Provide 2 accessible seats at tables.	40.00	60.00	FY2027	2016
Republic Aquatic Center (RAC)	Picnic tables (Blue)	Provide 1 additional accessible seat at tables.	20.00	40.00	FY2027	2016

Program, Facility, Activity, Service	Individual Feature or Characteristic	Existing Barrier Description / Findings	Cost estimate for barrier removal		Estimated Date of Removal	Date of Removal
			Low	High		
					Complete	In Progress
Republic Aquatic Center (RAC)	First Aid/cooling station	Install signage at door. Lower mirror to 40" AFF.	70.00	125.00	FY2024	
Republic Aquatic Center (RAC)		Total Estimates Low/High	9,020.00	11,315.00		3/9
Senior Friendship Center	Parking lot East	Reduce slope in accessible parking areas to maximum slope of 1:48. Restripe accessible parking spots to have 5ft wide aisles between spaces.	5,500.00	5,500.00	FY2016	7/2016
Senior Friendship Center	Pedestrian ingress Front (North)	Adjust door to maximum 5 lb pressure to open and minimum 5 seconds closing time.	20.00	30.00	FY2017	
Senior Friendship Center	Toilet room/dining hall Men's	Insulate lavatory pipes, lower coat hook to 48" AFF, move grab bar to allow for 1.5" from toilet tank, move toilet flush handle to open side of tank.	240.00	255.00	FY2023	
Senior Friendship Center	Toilet room/dining hall Women's	Insulate lavatory pipes, lower coat hook to 48" AFF, move grab bar to allow for 1.5" from toilet tank,	95.00	145.00	FY2022	
Senior Friendship Center	Toilet room/craft room Men's	Move toilet paper dispenser. Adjust door to maximum 5 lb pressure to open and minimum 5 seconds closing time.	35.00	55.00	FY2017	
Senior Friendship Center	Toilet room/craft room Women's	Move toilet paper dispenser, move toilet flush handle to open side of tank. Adjust door to maximum 5 lb pressure to open and minimum 5 seconds closing time.	180.00	265.00	FY2017	
Senior Friendship Center	Outside picnic table	Provide one accessible seat at table minimum.	20.00	40.00	FY2028	2016
Senior Friendship Center		Total Estimates Low/High	6,090.00	6,290.00		2/8
City Hall	East parking lot	Raise accessible parking signage to 60".	120.00	140.00	FY2017	
City Hall	Main Street Parking	Widen van accessible aisle to 8 ft. Raise signage to 60" AFF. Ensure accessible parking is nearest to accessible routes. Reduce slope within accessible parking spaces to no steeper than 1:48.	1,910.00	2,380.00	FY2018	
City Hall	Accessible pedestrian route	Install correct curb cut, remove and replace sidewalk	3,800.00	4,700.00	FY2018	
City Hall	Pedestrian access at North doors	Widen outer door to 32" wide minimum (alternative - remove double doors and install single automated door). Increase distance between doors in vestibule. Install accessible entrance signage on building exterior.	1,500.00	2,500.00	FY2018	
City Hall	Pedestrian access at South door	Reduce slope at door entryway. Install accessible entrance signage on building exterior.	280.00	375.00	FY2019	
City Hall	Pedestrian access door- Clerk to Chambers	Remove round door knobs on interior access doorways.	1,680.00	2,520.00	FY2020	
City Hall	Customer service desk	Lower counter to 36" AFF for at least 36" wide.	650.00	800.00	FY2019	
City Hall	Council Chambers podium (microphone)	Allow for wheel chair access and use by individuals in a sitting position.	150.00	200.00	FY2018	
City Hall	Men's Toilet room Finance Dept.	Reconfigure toilet rooms or combine to create one unisex accessible toilet room.	40,000.00	60,000.00	FY2024	
City Hall	Women's Toilet room Finance Dept.	Reconfigure toilet rooms or combine to create one unisex accessible toilet room.	0.00	0.00	Not stated	
City Hall	Men's Toilet room Admin. Dept.	Reconfigure toilet rooms or combine to create one unisex accessible toilet room.	4,500.00	5,000.00	FY2020	
City Hall	Women's Toilet room Admin. Dept.	Reconfigure toilet rooms or combine to create one unisex accessible toilet room.	4,500.00	5,000.00	FY2020	
City Hall		Total Estimates Low/High	59,090.00	83,615.00		0/12
Public Works	Main St. parking	Provide accessible van parking available. Parking space is directly in front of the curb ramp. Make parking space available access aisle.	35.00	50.00	FY2016	7/2016
Public Works	Pedestrian access front	Reduce slope of curb ramp to less than 1:12.	1,000.00	1,200.00	FY2022	
Public Works	Customer service counter	Lower counter height to 36" for a minimum of 36" width.	350.00	2,000.00	FY2021	

Program, Facility, Activity, Service	Individual Feature or Characteristic	Existing Barrier Description / Findings	Cost estimate for barrier removal		Estimated Date of Removal	Date of Removal
			Low	High		
					Complete	In Progress
Public Works	Main St. South front ingress	Reduce threshold height to no more than ¾ inch high with the top ½ inch beveled no steeper than 1:2. Adjust door for 5 lbs force and 5 seconds closing time,	150.00	200.00	FY2021	
Public Works	Ramp at south end of plan room	Reduce running slope to less than 1:12	150.00	300.00	FY2024	
Public Works	Toilet room men's	Install longer grab bars to extend further from corner.	50.00	75.00	FY2024	
Public Works	Toilet room women's	Reconfigure/alter room-compartment for ADA clearances. Multiple issues.	4,500.00	5,000.00	FY2025	
Public Works	Break room	Remove step and reduce ramp slope to enter room. Widen doorways to 32" minimum.	2,000.00	3,000.00	FY2031	
Public Works		Total Estimates Low/High	8,235.00	11,825.00		1/8
Community Development	East side Main St. parking	Reduce cross slope in sidewalk, install curb ramp at south accessible parking space. Reduce slope in accessible parking space. Install parking signage.	955.00	1,190.00	FY2019	
Community Development	Pedestrian access to building	Reduce sidewalk cross slope to less than 1:48. Provide curb ramp at accessible parking. Reduce cross slope on landing at top of corner curb ramp to less than 1:48.	6,760.00	8,400.00	FY2020	
Community Development	Front ingress	Reduce threshold height to less than ¾" in total. Reduce slope at entry way to less than 1:48.	340.00	420.00	FY2018	
Community Development	Customer service counter	Lower 36" wide counter section to 36" in height with knee and toe space as required.	1,500.00	1,800.00	FY2024	
Community Development	conference room	Provide tactile signage at entrance to conference room.	40.00	75.00	FY2024	
Community Development	Toilet room men's	Multiple issues. Provide accessible restrooms in offices.	6,000.00	12,000.00	FY2025	
Community Development	Toilet room women's	Multiple issues. Provide accessible restrooms in offices.	4,000.00	8,000.00	FY2025	
Community Development	Water fountain	Reduce height of fountain to 36" max. Provide 30"x48" clear space in front of fountain.	45.00	75.00	FY2030	
Community Development		Total Estimates Low/High	19,640.00	31,960.00		0/9
Fire Station 1	Parking	Reduce cross slope in parking area to less than 1:48.	1,600.00	2,000.00	FY2020	
Fire Station 1	Pedestrian access to building	Reduce curb ramp at parking access to less than 1:12 running slope.	1,000.00	1,200.00	FY2020	
Fire Station 1	Front ingress	Reduce slope outside entry door (60"d) to less than 1:48.	800.00	1,200.00	FY2020	
Fire Station 1	Toilet room men's	Adjust door for 5 lbs force and 5 seconds closing time, lower mirror to 40" AFF, lower soap to 48", relocate grab bars horizontally to between 33-36" AFF.	105.00	170.00	FY2025	
Fire Station 1	Toilet room women's	Adjust door for 5 lbs force and 5 seconds closing time, relocate grab bars to between 33- 36" AFF, relocate side grab bar to 54" from corner,	60.00	100.00	FY2024	
Fire Station 2		Total Estimates Low/High	3,565.00	4,670.00		0/5
Fire Station 2	Pedestrian access to building	Adjust door to close 5 seconds minimum time.	20.00	30.00	FY2024	
Fire Station 2	Toilet room men's	Lower mirror height to less than 40", move toilet to within 18" from wall, move side grab bar away from corner to 54" minimum, move rear grab bar away from corner to 24" minimum from center of toilet, move flush handle on toilet to open side of room,	290.00	430.00	FY2025	
Fire Station 2	Toilet room women's	Lower mirror to less than 40" AFF, move side grab bar to no less than 54" from corner, move rear grab bar 42" from corner,	70.00	120.00	FY2024	
Fire Station 2	Toilet room common area	lower mirror to 40" high maximum	30.00	50.00	FY2024	
Fire Station 3		Total Estimates Low/High	410.00	630.00		0/4
Animal Control buildings	Kennel ingress	Provide accessible entry surface, provide accessible door hardware.	60.00	90.00	FY2025	

Program, Facility, Activity, Service	Individual Feature or Characteristic	Existing Barrier Description / Findings	Cost estimate for barrier removal		Estimated Date of Removal	Date of Removal
			Low	High		
					Complete	In Progress
Animal Control buildings	Office access	Provide accessible entry to office and service desk.	2,000.00	2,500.00	FY2023	
Animal Control buildings	Parking	Provide accessible parking and route to buildings.	6,480.00	7,080.00	FY2024	
Animal Control buildings	Service desk	Provide for clear floor space in front of desk, provide accessible route to desk, provide counter at least 36" wide.	0.00	0.00	Not stated	
Animal Control buildings		Total Estimates Low/High	8,540.00	9,670.00		0/4
McKee Park	Street parking	Public parking is not provided at this location. Street parking only. Recommend accessible parking.	10,000.00	12,000.00	FY2024	
McKee Park	Playground equipment	Provide ramp into playground area.	1,000.00	1,500.00	FY2025	
McKee Park	Pedestrian access to playground	Provide accessible route between sidewalk access or street parking and playground.	2,400.00	3,000.00	FY2026	
McKee Park		Total Estimates Low/High	13,400.00	16,500.00		0/3
J. R. Martin Park	Parking lot upper	Provide "Van Accessible" signs on existing accessible parking signposts.	240.00	280.00	FY2016	5/2016
J. R. Martin Park	Parking lot lower	Provide "Van Accessible" signs on existing accessible parking signposts.	240.00	280.00	FY2019	
J. R. Martin Park	Pedestrian access to tennis courts	Provide accessible route between pedestrian path and tennis courts.	2,300.00	3,220.00	FY2025	
J. R. Martin Park	Tennis courts spectator bleachers (2)	Provide accessible route from pedestrian path to bleachers; Provide clear space for accessible seating/wheelchair spaces at ends of bleachers.	2,600.00	3,640.00	FY2025	
J. R. Martin Park	Tennis court gate West side North	Provide 36" wide gate at court fencing.	200.00	250.00	FY2024	
J. R. Martin Park	Tennis court gate West side South	Provide 36" wide gate at court fencing.	200.00	250.00	FY2024	
J. R. Martin Park	Tennis court gate East side North	Provide 36" wide gate at court fencing.	200.00	250.00	FY2024	
J. R. Martin Park	Tennis court gate East side South	Provide 36" wide gate at court fencing.	200.00	250.00	FY2024	
J. R. Martin Park	Park Toilet rooms	Relocate toilet paper dispensers 7-9" maximum distance from handicap toilets.	15.00	15.00	FY2016	5/2016
J. R. Martin Park	Water fountains	Provide 48" clear surface around fountain.	0.00	0.00	Not stated	
J. R. Martin Park	Playground Large Castle	Replace ramp into playground area/enclosure	1,000.00	1,500.00	FY2023	2016
J. R. Martin Park	Pedestrian access to large playground	Provide accessible route to playground.	2,200.00	3,080.00	FY2024	6/2017
J. R. Martin Park	Pedestrian access to triples slides	Provide accessible route to playground.	1,625.00	2,275.00	FY2024	2016
J. R. Martin Park	Park benches	Provide 30"x48" clear space with solid surface at end of benches and 36" travel around minimum of 20% of benches.	875.00	1,100.00	FY2025	
J. R. Martin Park	Pedestrian access to large pavilion	Remove vertical fault where concrete has settled at connection to pavilion slab. Same issue exists with both (north and south) access walks.	360.00	420.00	FY2024	
J. R. Martin Park	Pedestrian access to small pavilion	Provide accessible pedestrian route to pavilion.	750.00	1,050.00	FY2025	
J. R. Martin Park		Total Estimates Low/High	13,005.00	17,860.00		5/16

Program, Facility, Activity, Service	Individual Feature or Characteristic	Existing Barrier Description / Findings	Cost estimate for barrier removal		Estimated Date of Removal	Date of Removal
			Low	High		
					Complete	In Progress
AMP	Movie screen	Closed captioning	0.00	0.00	FY2016	2016
AMP	Sound system	CONVENTIONAL INDUCTION LOOP Transmitter: Amplifier drives an induction loop that surrounds listening area. Receivers: a)Personal hearing aid with telecoil. b)Pocket size induction receiver with earphone or headset. c)Self-contained wand. d)Telecoil inside plastic chassis which looks like a BTE, ITE, or canal hearing aid.	4,000.00	6,000.00	FY2025	
AMP		Total Estimates Low/High	4,000.00	6,000.00		1/2
Owen Park	Parking lot	Reduce slope in accessible parking space to less than 1:48.	800.00	1,000.00	FY2022	
Owen Park	Pedestrian access to playground	Provide accessible route between parking and playground.	3,750.00	5,250.00	FY2023	
Owen Park	Benches	Provide 30"x48" clear space with solid surface at end of benches and 36" travel around minimum of 20% of benches.	210.00	300.00	FY2025	
Owen Park		Total Estimates Low/High	4,760.00	6,550.00		0/3
Shuyler Creek Trail	Walking trail	Provide asphalt repair on trail west of Oakwood crossing.	1,500.00	2,100.00	FY2025	2016
Shuyler Creek Trail	Benches	Provide clear space of 30" w and 48" d at one end of at least 20% of benches for wheel chair seating. Provide accessible route to bench on east end of trail (loop).	365.00	520.00	FY2028	
Shuyler Creek Trail	Trailhead signage	Provide information on signage describing accessibility of the trail. For example, average and maximum slopes and cross slopes, length of trail, type of surface, typical and minimum trail width.	1,000.00	1,500.00	FY2025	
Shuyler Creek Trail	Pedestrian access	Provide curb ramp from Lee Street to trailhead at east end of trail.	1,000.00	1,200.00	FY2022	
Shuyler Creek Trail	Picnic tables	Provide at least one accessible seat at picnic area on east end of trail.	600.00	800.00	FY2028	
Shuyler Creek Trail		Total Estimates Low/High	4,465.00	6,120.00		1/5
Brookline Park	Parking lot	Provide "van accessible" sign at accessible parking space. (60" AFF). Ensure slope in accessible space is less than 1:48.	800.00	1,000.00	FY2022	
Brookline Park	Pedestrian access to pavilion	Provide accessible route to pavilion from parking.	1,000.00	1,400.00	FY2025	
Brookline Park	Benches	Provide 30"x48" clear space with solid surface at end of benches and 36" travel around minimum of 20% of benches.	365.00	520.00	FY2028	
Brookline Park	Pedestrian access to playground	Provide accessible route to playground from parking.	5,000.00	7,000.00	FY2029	
Brookline Park		Total Estimates Low/High	7,165.00	9,920.00		0/4
Moore Park	Parking lot	Provide accessible parking, signage, surfacing, etc.	0.00	0.00	Not stated	IN PROGRESS
Moore Park	Pedestrian route from parking to trail	Provide accessible route to trail	0.00	0.00	Not stated	IN PROGRESS
Moore Park	Pedestrian route from public sidewalks	Provide accessible routes between adjacent sidewalks and park and parking lot.	0.00	0.00	Not stated	IN PROGRESS
Moore Park	Trailhead	Provide signage as to trail accessibility	1,000.00	1,500.00	FY2025	IN PROGRESS
Moore Park	Pedestrian trail	Reduce excessive slopes and cross slopes, remove vertical faults in trail surface. Clear trails of vertical obstacles to 80" above surface.	27,500.00	38,500.00	FY2025	IN PROGRESS
Moore Park	Bridges	Provide 1 bridge with accessible features/approaches.	20,000.00	25,000.00	FY2025	IN PROGRESS
Moore Park	Benches and other outdoor features	Provide clear spaces for seating and maneuvering around benches and trash receptacles.	0.00	0.00	Not stated	IN PROGRESS

Program, Facility, Activity, Service	Individual Feature or Characteristic	Existing Barrier Description / Findings	Cost estimate for barrier removal		Estimated Date of Removal	Date of Removal
			Low	High		
					Complete	In Progress
Moore Park		Total Estimates Low/High	48,500.00	65,000.00		0/7
Garoutte Field	Parking lot -east	Gravel lot of undetermined number of spaces with no markings, specified accessible spaces. Grading is varied. No accessible route from lot to facilities.	62,000.00	67,000.00	FY2022	
Garoutte Field	Toilet rooms	Reconfigure toilet rooms for accessibility	140,000.00	160,000.00	FY2025	
Garoutte Field	Pedestrian access to Toilet rooms	Provide accessible route to Toilet rooms	0.00	0.00	Not stated	
Garoutte Field	Concrete bleachers	Provide handrails, Provide wheelchair seating	0.00	0.00	Not stated	
Garoutte Field	Pedestrian access to concrete bleachers	Provide accessible route to bleachers.	0.00	0.00	Not stated	
Garoutte Field	Pedestrian access to concession stand	Provide accessible route to concession stand.	0.00	0.00	Not stated	
Garoutte Field		Total Estimates Low/High	202,000.00	227,000.00		0/6
Miller Park	West Parking lot for pavilion	Provide disabled parking near pavilion. Provide at least one accessible parking space nearest to accessible route.	2,555.00	3,410.00	FY2023	
Miller Park	Paved walking trail	Fill multiple cracks in trail surface with horizontal gaps greater than 1/2" to eliminate hazards.	5,035.00	5,035.00	FY2016	8/2016
Miller Park	Playground	Install access ramp at entrance. Install 2 accessible swings. Construct fence around playground area for child security and safety. Rake mulch to eliminate excessive vertical fault at playground equipment ramp entrance. Relocate bench on south side of play area to accommodate 30" x 48" wheelchair clear ground space at end of bench.	10,875.00	13,620.00	FY2025	
Miller Park	Pedestrian access to playground	Provide accessible route to playground from west parking lot	5,000.00	7,000.00	FY2025	
Miller Park	West Parking lot for playground	Provide at least one accessible parking space with curb cut near playground. Closest disabled parking in front of Activities building.	1,155.00	1,390.00	FY2022	
Miller Park	Park picnic table and BBQ	Provide 48' clear surface around grill and table.	2,240.00	2,800.00	FY2028	
Miller Park	Pedestrian access to picnic table and Grill	Provide accessible route to table and grill area from parking.	1,875.00	2,625.00	FY2028	
Miller Park		Total Estimates Low/High	28,735.00	35,880.00		1/7
Bervin White BB & SB Complex	Pavilion picnic tables	Install at least one accessible seat at picnic tables for each 24 linear feet of table space.	600.00	800.00	FY2026	
Bervin White BB & SB Complex	Toilet room Men's	Lower coat hook, lower 1 urinal to 17" at lip, remove round handle lavatory faucet, move toilet within spec from side wall and raise to 17-19" AFF, install door pull on stall door, insulate pipes below lavatory, move TP dispenser downward.	615.00	1,050.00	FY2024	
Bervin White BB & SB Complex	Toilet room Women's	Lower coat hook, remove round handle lavatory faucet, move toilet within spec from side wall and raise to 17-19" AFF, install door pull on stall door, insulate pipes below lavatory, move TP dispenser downward.	305.00	555.00	FY2024	
Bervin White BB & SB Complex	Bleachers/seating ballfield 3	Provide level clear space for wheelchair spectator seating	100.00	150.00	FY2023	
Bervin White BB & SB Complex	Bleachers/seating ballfield 4	Provide level clear space for wheelchair spectator seating	2,580.00	3,860.00	FY2024	
Bervin White BB & SB Complex	Bleachers/seating ballfield 5	Provide level clear space for wheelchair spectator seating	1,000.00	1,500.00	FY2024	
Bervin White BB & SB Complex	Bleachers/seating ballfield 6	Provide level clear space for wheelchair spectator seating	1,150.00	1,720.00	FY2024	
Bervin White BB & SB Complex	Player seating ballfield 1	Provide accessible route to dugout	100.00	150.00	FY2023	
Bervin White BB & SB Complex	Player seating ballfield 2	Provide accessible route to dugout	100.00	150.00	FY2023	

Program, Facility, Activity, Service	Individual Feature or Characteristic	Existing Barrier Description / Findings	Cost estimate for barrier removal		Estimated Date of Removal	Date of Removal
			Low	High		
					Complete	In Progress
Bervin White BB & SB Complex	Player seating ballfield 3	Provide accessible route to dugout, provide player seating	10,120.00	14,380.00	FY2025	
Bervin White BB & SB Complex	Player seating ballfield 4	Provide accessible route to dugout, provide player seating	690.00	1,035.00	FY2024	
Bervin White BB & SB Complex	Player seating ballfield 5	Provide accessible route to dugout, provide player seating	100.00	150.00	FY2023	
Bervin White BB & SB Complex	Player seating ballfield 6	Provide accessible route to dugout, provide player seating	100.00	150.00	FY2023	
Bervin White BB & SB Complex	Pedestrian access to ballfield 4	Provide accessible route to field	3,940.00	5,905.00	FY2025	
Bervin White BB & SB Complex	Pedestrian access to ballfield 5	Provide accessible route to field	4,800.00	7,200.00	FY2025	
Bervin White BB & SB Complex	Pedestrian access to ballfield 6	Provide accessible route to field	6,170.00	9,250.00	FY2025	
Bervin White BB & SB Complex	Parking lot West	Pave parking area. Provide at least two accessible parking spaces closest to accessible route.	0.00	0.00	Not stated	
Bervin White BB & SB Complex	Parking lot East	Install "van accessible" signage.	240.00	280.00	FY2021	
Bervin White BB & SB Complex	Batting cage	Provide accessible route to batting cage.	960.00	1,440.00	FY2028	
Bervin White BB & SB Complex		Total Estimates Low/High	33,670.00	49,725.00		0/19
Pocket Park	Street parking	Provide striping to prevent parking in front of curb cut.	35.00	50.00	FY2016	7/2016
Pocket Park	Signage	Provide accessible parking signage	120.00	140.00	FY2022	7/2016
Pocket Park		Total Estimates Low/High	155.00	190.00		2/2